



# Emission Test Certificate

Thursday, 7<sup>th</sup> July 2011

Supplier: Textstyle Australia (3/63-71 Bayfield Road East, Bayswater, Victoria, 3153)

Sample Description: Metroshade Fabric

Date Tested: June 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

| Specification   | Metroshade   |
|---|--|
| <b>Green Building Council of Australia</b><br><b>Green Star Office Design IEQ-13</b><br><b>Green Star Office Interiors IEQ-11</b> |  |
| Total Volatile Organic Compound emission rate<br><0.5 mg/m <sup>2</sup> /hr   | Total Volatile Organic Compound emission rate<br><0.004mg/m <sup>2</sup> /hr |

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV110611

OHS & Environmental Care

Sustainability

Advanced Laboratory/Analytical Services

Technology & Innovation